



CITY OF PERRIS


DEVELOPMENT SERVICES DEPARTMENT

PLANNING DIVISION

135 NORTH D STREET, PERRIS, CA 92570-2200
(951) 943-5003

LEGEND:

- ① WILKINS MODEL 375XL
- ② WYE TYPE STRAINER MODEL SXL
SIZE TO MATCH BACKFLOW
- ③ BRASS RISER, SIZE TO MATCH
BACKFLOW
- ④ CONCRETE BASE
- ⑤ FINISH GRADE 1" BELOW
CONCRETE PAD
- ⑥ COMPACTED SUBGRADE
- ⑦ FROM METER
- ⑧ STRONG BOX ENCLOSURE
- ⑨ SENTRY GUARD CABLE
INSTALL PER MANUFACTURER
- ⑩ SENTRY UNION GUARD
INSTALL PER MANUFACTURER
- ⑪ BRASS UNION
(SIZE AS REQUIRED)
- ⑫ BRASS ELBOW



NOTES:

1. INSTALL BACKFLOW PREVENTER AS REQUIRED BY LOCAL CODES, HEALTH DEPARTMENT STANDARDS, AND MANUFACTURER'S DIRECTIONS. CONTRACTOR SHALL VERIFY LOCAL REQUIREMENTS PRIOR TO INSTALLATION. FINAL BACKFLOW PREVENTER LOCATION TO BE DETERMINED IN THE FIELD.
2. SCREEN WITH SHRUBS WHEN POSSIBLE

N.T.S.

REDUCED PRESSURE BACKFLOW PREVENTER (1" - 2")

I-6

DATE: 08/12/24